LISTING SERVICE

LISTING No.   7271-0694:145   Page 1 of 1

CATEGORY: Ionization Smoke Detector

LISTEE: Fire Control Instruments, 301 2nd Avenue, Waltham, MA 02451-1133
            Contact: Anthony J. Shalna (781) 471-3000*

DESIGN: Model SBS-1101 ionization type smoke detector. Refer to listee's data sheet for detailed
            product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances
            and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as an ionization smoke detector for use with separately listed compatible fire alarm
            control units.

NOTE: Formerly 7256-0694:145

XLF: 7271-1209:102

*Rev. 06-11-2002

Date Issued: **JUNE 21, 2003**   Listing Expires **June 30, 2004**

Authorized By: **DIANE K. AREND**, Senior Deputy
            Program Manager